

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7271-0328:148 Page 1 of 1

CATEGORY: Ionization Smoke Detector

LISTEE: Potter, 2081 Craig Road, St. Louis MO 63146
Contact: Brad Serangeli (314) 878-4321

DESIGN: Model AIS analog addressable ionization type smoke detector. Unit consists of resistors, capacitors, diodes, transistors, LED, diodes and ionization chamber, mounted on a printed wiring board inside an enclosure. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 39.5 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, electrical rating and UL label.

APPROVAL: Listed as ionization type smoke detector for use with separately listed compatible fire alarm control units.

XLF: 7271-0410:148

09-11-2001



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 20, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager